

STARKVILLE FIRE DEPARTMENT

ENGINE COMPANY INSPECTION

Date _____ Shift _____ Engine _____ Phone _____
 Business Name _____ Address _____
 Personnel Inspecting _____

CHECK IF VIOLATION FOUND	
1. Address shall be visible from the street IFC 505.1	
2. FDC shall be labeled IFC 912.4	
3. FDC shall be in good working condition with caps IFC 912.3.1	
4. The working space around a FDC shall be min. 36 inches IFC 912.3.2	
5. Exit doors shall swing outward IFC 1008.1.2	
6. Exit doors shall be unlocked and functional without special knowledge IFC 1008.1.9	
7. Approved hardware shall be attached to all exit doors IFC 1008.1.9.1	
8. Exit paths and corridors shall be clear and unobstructed IFC 1018.3	
9. Means of egress area shall be free of combustible storage IFC 315.3.2	
10. Current privilege license must be displayed ordinance # 102-47;49	
11. Exit lights shall work properly IFC 1011.13	
12. Emergency lights shall work properly IFC 604.5	
13. All junction boxes, electric panels and outlets shall have an approved cover IFC 605.6	
14. There shall be a minimum of 36 inches in front of electrical panel IFC 605.3	
15. Extension cords shall be used in a proper manner IFC 605.5	
16. Extension cords shall be protected from physical damage IFC 605.5	
17. Surge protector shall plug directly into an electrical outlet IFC 605.4.2	
18. Fire Extinguisher shall be serviced annually IFC 906.2 NFPA 10	
19. Fire Extinguishers shall be mounted to the wall or in cabinet IFC 906.9	
20. There shall be a min. of 18 inches of clearance below sprinkler heads IFC 315.3.1	
21. A clear workspace shall be maintained around the fire sprinkler riser IFC 901.4.6	
22. Boiler, Mechanical and Electrical rooms shall be free of combustibles IFC 315.3.3	
23. Gas cylinders shall be secured to wall or portable carrier IFC 5303.5.3	
24. Fire alarm system shall be serviced annually IFC 907.8 NFPA 72	
25. Fire Sprinkler System shall be serviced annually IFC 901.6 NFPA 25	
NO VIOLATIONS WERE NOTED DURING THE INSPECTION	

Comments: _____

Business Representative _____